

Замеры максимальных нагрузок по ПС 35/6 "Зеленхоз" на "_16-17_"_декабря_2020г. ООО "Варистор"

№ п/п	Время местное	Ввод 1Т, 6 кВ, кВт, кВар, А	Положени е РПН	U, кВ	КУ
1	05:00-06:00	1440.00	III	6.3	3600
		324			
		132			
2	06:00-07:00	1800.00			
		324			
		148			
3	07:00-08:00	2160.00			
		324			
		160			
4	08:00-09:00	1872			
		288			
		160			
5	09:00-10:00	1548.00			
		288			
		140			
6	10:00-11:00	1548			
		324			
		140			
7	11:00-12:00	1548.00			
		324			
		140			
8	12:00-13:00	1440			
		360			
		140			
9	13:00-14:00	1512			
		324			
		150			
10	14:00-15:00	1512			
		288			
		150			
11	15:00-16:00	1620			
		324			
		150			
12	16:00-17:00	1980			
		396			
		140			
13	17:00-18:00	2160			
		360			
		160			

14	18:00-19:00	2016
		360
		160
15	19:00-20:00	1620
		288
		160
16	20:00-21:00	1620
		288
		162
17	21:00-22:00	1548
		252
		170
18	22:00-23:00	1548
		288
		165
19	23:00-24:00	1548
		288
		150
20	00:00-01:00	1620
		324
		133
21	01:00-02:00	1800
		360
		130
22	02:00-03:00	1332
		288
		130
23	03:00-04:00	1368
		288
		130
24	04:00-05:00	1440
		288
		130

Гл. инженер

Сосновский С.В.

Замеры максимальных нагрузок по ПС 35/6 "Аэропорт" на "_16-17_"_декабря_2020г. ООО "Варистор"

№ п/п	Время местное	Ввод 1Т, 6 кВ, кВт, кВар, А		Ввод 2Т, 6 кВ, кВт, кВар, А		Положение РПН 1Т	Положение РПН 2Т	U, кВ	КУ
1	05:00-06:00	0.00	360.00	I	I			6.3	2400
		0	0						
		0	50						
2	06:00-07:00	0.00	415.20						
		0	0						
		0	52						
3	07:00-08:00	0.00	456.00						
		0	0						
		0	56						
4	08:00-09:00	0.00	600						
		0	0						
		0	53						
5	09:00-10:00	0.00	532.80						
		0	0						
		0	60						
6	10:00-11:00	24	225.6						
		0	0						
		0	61						
7	11:00-12:00	0.00	264.00						
		0	0						
		0	50						
8	12:00-13:00	0.00	576						
		0	0						
		0	60						
9	13:00-14:00	0.00	624						
		0	0						
		0	63						
10	14:00-15:00	0.00	624						
		0	0						
		0	65						
11	15:00-16:00	0.00	504						
		0	0						
		0	60						
12	16:00-17:00	0.00	504						
		0	0						
		0	60						
13	17:00-18:00	0.00	496.8						
		0	0						
		0	56						
14	18:00-19:00	24	264						
		0	0						
		0	63						
15	19:00-20:00	0.00	235.2						
		0	0						
		0	63						
16	20:00-21:00	0.00	456						
		0	0						
		0	62						
17	21:00-22:00	0.00	511.2						
		0	0						
		0	60						
18	22:00-23:00	0.00	456						
		0	0						
		0	55						
19	23:00-24:00	0.00	412.8						
		0	0						
		0	55						
20	00:00-01:00	0.00	412.8						
		0	0						
		0	47						
21	01:00-02:00	0.00	403.2						
		0	0						
		0	40						
22	02:00-03:00	0.00	384						
		0	0						
		0	40						
23	03:00-04:00	0.00	384						
		0	0						
		0	40						
24	04:00-05:00	0.00	360						
		0	0						
		0	50						

Замеры максимальных нагрузок по ПС 110/6 "Таловка" на "_16-17_"_декабря_2020г. ООО "Варистор"

№ п/п	Время местное	Ввод 1Т, 10 кВ, кВт, кВар, А	Положение РПН	КУ
1	05-00	512.00	II	3000
2	06-00	572.00		
3	07-00	632.00		
4	08-00	721		
5	09-00	718.00		
6	10-00	747		
7	11-00	729.00		
8	12-00	720		
9	13-00	741		
10	14-00	743		
11	15-00	661		
12	16-00	671		
13	17-00	735		
14	18-00	753		
15	19-00	787		
16	20-00	748		
		792		

17	21-00	
		728
18	22-00	
		703
19	23-00	
		628
20	00-00	
		593
21	01-00	
		563
22	02-00	
		559
23	03-00	
		561
24	04-00	
		520
25	05-00	

Гл. инженер

Сосновский С.В.