

Замеры максимальных нагрузок по ПС 110/10 "Таловка" на "\_15-16\_"\_июня\_2022г. ООО "Варистор"

№ п/п	Время местное	Ввод 1Т, 10 кВ, кВт, кВар, А	Положен ие РПН	КУ
1	05-00	362,00	II	3000
		216		
2	06-00	366,00		
		196		
3	07-00	480,00		
		184		
4	08-00	614		
		192		
5	09-00	700,00		
		196		
6	10-00	744		
		188		
7	11-00	676,00		
		188		
8	12-00	682		
		180		
9	13-00	686		
		196		
10	14-00	648		
		208		
11	15-00	654		
		210		
12	16-00	616		
		194		
13	17-00	652		
		210		
14	18-00	590		
		222		
15	19-00	550		
		184		
16	20-00	662		
		226		
17	21-00	654		
		196		

18	22-00	724
		216
19	23-00	630
		184
20	00-00	528
		204
21	01-00	384
		206
22	02-00	312
		218
23	03-00	298
		208
24	04-00	278
		210
25	05-00	324
		218

Гл. инженер  Сосновский С.В.

Замеры максимальных нагрузок по ПС 35/10 "Макбур" на "\_15-16\_" июня\_2022г. ООО "Варистор"

№ п/п	Время местное	Ввод 1Т, 35 кВ,		Положен ие РПН 1Т	Положен ие РПН 2Т	U, кВ	КУ
		кВт, кВар,	А				
1	05:00-06:00	0,00	160,65	V	V	6,3	14000
		0					
		0					
2	06:00-07:00	0,00	160,68				
		0					
		0					
3	07:00-08:00	0,00	160,72				
		0					
		0					
4	08:00-09:00	0,00	160,758				
		0					
		0					
5	09:00-10:00	0,00	160,80				
		0					
		0					
6	10:00-11:00	0,00	160,837				
		0					
		0					
7	11:00-12:00	0,00	160,88				
		0					
		0					
8	12:00-13:00	0,00	160,918				
		0					
		0					
9	13:00-14:00	0,00	160,957				
		0					
		0					
10	14:00-15:00	0,00	160,996				
		0					
		0					
11	15:00-16:00	0,00	161,035				
		0					
		0					
12	16:00-17:00	0,00	161,075				
		0					
		0					
13	17:00-18:00	0,00	161,115				
		0					
		0					
14	18:00-19:00	0,00	161,153				
		0					
		0					
15	19:00-20:00	0,00	161,189				
		0					
		0					
16	20:00-21:00	0,00	161,224				
		0					
		0					
17	21:00-22:00	0,00	161,259				
		0					
		0					
	22:00-	0,00	161,294				

18	22:00-	0	
	23:00	0	
19	23:00-	0,00	161,33
	24:00	0	
		0	
20	00:00-	0,00	161,365
	01:00	0	
		0	
21	01:00-	0,00	161,401
	02:00	0	
		0	
22	02:00-	0,00	161,436
	03:00	0	
		0	
23	03:00-	0,00	161,472
	04:00	0	
		0	
24	04:00-	0,00	161,507
	05:00	0	
		0	

Гл. инженер



Сосновский С.В.

Замеры максимальных нагрузок по ПС 35/6 "Зеленхоз" на "\_15-16\_"\_июня\_2022г. ООО"Варис

№ п/п	Время местное	Ввод 1Т, 6 кВ, кВт, кВар, А	Положение РПН	U, кВ	КУ
1	05:00-06:00	6769,46	III	6,3	3600
		1338,57			
		0			
2	06:00-07:00	6769,60			
		1338,64			
		0			
3	07:00-08:00	6769,74			
		1338,71			
		0			
4	08:00-09:00	6769,89			
		1338,77			
		25			
5	09:00-10:00	6770,30			
		1338,93			
		30			
6	10:00-11:00	6770,51			
		1339			
		50			
7	11:00-12:00	6770,69			
		1339			
		45			
8	12:00-13:00	6770,81			
		1339,07			
		40			
9	13:00-14:00	6770,95			
		1339,16			
		50			
10	14:00-15:00	6771,2			
		1339,22			
		45			
11	15:00-16:00	6771,33			
		1339,3			
		45			
12	16:00-17:00	6771,55			
		1339,38			
		25			
13	17:00-18:00	6771,79			
		1339,45			
		30			

14	18:00-19:00	6771,99
		1339,58
		20
15	19:00-20:00	6772,11
		1339,64
		20
16	20:00-21:00	6772,35
		1339,73
		10
17	21:00-22:00	6772,59
		1339,84
		15
18	22:00-23:00	6772,84
		1339,91
		15
19	23:00-24:00	6773,1
		1340,08
		10
20	00:00-01:00	6773,4
		1339,12
		20
21	01:00-02:00	6773,59
		1339,16
		10
22	02:00-03:00	6773,79
		1340,21
		15
23	03:00-04:00	6773,91
		1340,32
		15
24	04:00-05:00	6774,08
		1340,39
		15

Гл. инженер



Сосновский С.В.

Замеры максимальных нагрузок по ПС 35/6 "Аэропорт" на "\_15-16\_"\_июня\_2022г. ООО "Варистс

№ п/п	Время местное	Ввод 1Т, 6 кВ, кВт, кВар, А	Ввод 2Т, 6 кВ, кВт, кВар, А	Положение РПН 1Т	Положение РПН 2Т		
						U, кВ	KУ
1	05:00-06:00	9013,20	9424,36	II	II	6,3	2400
			2819,563				
			0				
2	06:00-07:00	9013,20	9424,43				
			2819,58				
			5				
3	07:00-08:00	9013,20	9424,51				
			2819,61				
			5				
4	08:00-09:00	9013,20	9424,576				
			2819,631				
			5				
5	09:00-10:00	9013,30	9424,65				
			2819,645				
			5				
6	10:00-11:00	9013,30	9424,704				
			2819,662				
			5				
7	11:00-12:00	9013,30	9424,79				
			2819,687				
			4				
8	12:00-13:00	9013,40	9424,914				
			2819,718				
			5				
9	13:00-14:00	9013,40	9424,999				
			2819,739				
			6				
10	14:00-15:00	9013,40	9425,13				
			2819,763				
			5				
11	15:00-16:00	9013,50	9425,24				
			2819,805				
			5				
12	16:00-17:00	9013,50	9425,308				
			2819,824				
			3				
13	17:00-18:00	9013,50	9425,372				
			2819,841				
			5				
14	18:00-19:00	9013,60	9425,411				
			2819,86				
			5				
15	19:00-20:00	9013,60	9425,911				
			2819,9				
			8				
16	20:00-21:00	9013,60	9425,994				
			2820,016				
			5				
17	21:00-22:00	9013,60	9426,112				
			2820,024				
			3				

18	22:00-23:00	9013,70	9426,19
			2820,041
			3
19	23:00-24:00	9013,70	9426,24
			2820,058
			3
20	00:00-01:00	9013,70	9426,293
			2820,078
			3
21	01:00-02:00	9013,70	9426,324
			2820,085
			1
22	02:00-03:00	9013,80	9426,363
			2820,095
			1
23	03:00-04:00	9013,80	9426,405
			2820,111
			1
24	04:00-05:00	9013,80	9429,441
			2820,124
			1

Гл. инженер



Сосновский С.В.